The Man Machine Interface

(Providing Critical Information, Anytime, Anywhere)

Walter W. Jones
Richard W. Bukowski
National Institute of Standards and
Technology

May 13, 2001



Background

Fire alarm systems in large buildings incorporate a display for the fire service:

Location of alarms, device type, sequence

"... to enable responding personnel to identify the location of a fire quickly and accurately and to indicate the status of emergency equipment or fire safety functions that might affect the safety of occupants ..."

Located in fire command center or near likely point of entry by the responding fire service.





The Concerns of the Fire Service







Improve Information Transfer: When, Where and How

Questions we asked at focus groups:

What do you want to know?

When do you want to know it?

Where do you want to know it?

How should it be presented?





Fire Service Needs

At Dispatch

Confidence in alarm, size and growth rate of the fire

On Arrival

Location of the fire, the occupants, current conditions

How to get to the fire

Staging areas, standpipes, other resource or safety issues

During the Incident

Fire spread and growth, area(s) involved

Systems status, i.e., ventilation

Location of fire fighters

Controls for communications and ventilation





Incident Management

Initial systems report

Systems active and operating Areas occupied

Incident management information

Current and "look ahead" conditions

Intuitive interface

High Resolution - building management, firehouse, ...

Panel – building panels, laptop/truck

Handheld – walkaround with Palm VII





Industry Perspective

- Develop Prototype Graphics for Panels
 Fire service doesn't use current panels
- Develop a Model of Sensors
 Current Detectors, then ...
- Do Large Scale Verification
 Conduct a Field Demonstration
- Consortium
 Siemens/Cerberus, Tyco/Simplex, GE/Honeywell/Notifier, SPX/EST, NEMA, NIST





NIST Perspective

Reliability of the signal (is it a fire?)

Multimode sensors Dispersed sensors

How big is the fire (if it is, how soon ...)
 Flashover, backdraft, limits of protective clothing

- Panel display "information wherever it is needed" NFPA 72 Task Group
- Tactical decision aid

Impact of ventilation, what happens?





Premise!

- Transducers will become common over the next decade
 - Micro-electronic sensors
 - Demand for sensor rich buildings
- Improvements in understanding can be made in utilizing the tremendous amount of data that will be available





A Synergy Among Fire Alarm Systems and Other Fire Safety Systems

1) Surveillance

Monitor ALL fire safety systems to assure that they will operate as designed, when needed

2) Notification

Surveillance information reduces the need for inspections Traditional role of notifying occupants and responders

3) Incident Management

Key information to enhance safety and efficiency of fire department operations





Major Tasks

- Extract alarm signals from current sensing technology, based on specified criteria. Use filtering at the panel rather than at the detector to identify patterns.
- Extract growth curve from T, OD, and other types of sensors.
- Develop a panel display and define the appropriate level of interaction based on the resolution of display and intended purpose.
- Develop an adaptive model which will start based on estimate of HRR and change based on extracting ät from comparison of T_p(t), T_e(t).
- Define a figure of merit for one or more detectors, the number of compartments to be protected and information available on building properties and current conditions.
- Full scale building demonstration of real time data delivery.







Detection and Alarm Project

- Low level sensing (early warning)
- High level sensing (fire following)
- Extract threat heat, smoke, CO …
- Confirmation through
 Multiple sensors
 Feature extraction and modeling
- Display
 High resolution, Laptop, wireless, beeper





NSI







Delivery of Information – Examples

Layer

Building Management

Building security, fire station, ...



3

Panel/Laptop

Laptop "in vehicles"
Building annunciator panel



2

Simple Display

Handheld device



1





NFPA 72 Task Group – This Year

Working groups

Icons (Usability, Color, Scaling)

Control functions

Information and presentation

Proposal closing date was November, 2000

For code cycle 2002

Proposed first as an appendix to NFPA 72

Scalable, Stylus, Icons, Inclusive, Intuitive





Illustrative Icons

 Drawn from Japanese standard and NFPA 170 symbols











- Function not present
- Function present and not active
- Function present and active





- Full Set at
 - http://panel.nist.gov/





Prototype Icons

Alarm	((⊙))	Stairwell (all ratings)	, popular	Occupant	£
Emergency Connection	<u></u>	Fire Department Key Box	*	Sprinkler	0
Exhaust Fan	6	Fire Pump	3 0	Smoke Vent	4
Exhaust Outlet	12	Fire Department Connection	(a)	Shutoff (W, E, G)	4
Siamese Connection	Y	Extinguishing System (i.e.CO ₂ and Halan)	•	Water Mist Sprinkler	ALC:
High Pressure Gas	[888]	Egress in Progress	K	Electrical Room	3
Manual Pull Station	<u></u>	Emergency Phone	•	Fire Service Access Point	*
Smoke Detector	s	Fire	ш	Elevator Equipment Room	EE
Standpipe	4	Gas Detector	G	Heat Detector	Н

27 proposed at the moment - Usability issues remain

BFSS Presentation, NFPA Spring Exposition, May 13, 2001





Two Other Tasks

Control Functions

Emergency voice communications - Zone, group, all call

Query sensors (incl. those not in alarm)

Manual ventilation control (stairways)

Elevators? (status of recall only?)

Presentation and Information

Somewhat intuitive (some training)

Consistent

Available in building, outside, in vehicles, handheld, ...

Familiar

Caution about color blindness





Information Possibilities

- Location of occupants (from energy mgmt sys)
- Location and condition of firefighters
- Performance of fire protection systems (within design parameters, low/high, failed)





NFPA 72 Task Group – Next Year

- Work the NFPA 72 process through ROP, ROC, TCC, and Standards Council
- Demonstrations of example implementations

Delaware (with CFSI) (wireless interface)


NIST

Commercial building






Implementation of Layers One and Three







Layer Two – The Control Interface







Reliability of the Signal


Method to compare curves
 Shape matching

Metric for the difference

Standard deviation of numerical models












One of our real room comparisons



BFSS Presentation, NFPA Spring Exposition, May 13, 2001





Transducer Data in Real Time

- Develop an algorithm of the operation of present day transducers
- Establish a protocol to test

This is the Detector Emulator...

Incorporate these signals





Model of a Transducer

To interpret the signals from a sensor, one needs to understand the reason

Example:


Chamber geometry (all physical aspects)

$$\frac{d}{dt}Cs = \frac{\alpha}{L}(Cs - Cg)$$






Using Sensor History to Predict Future Conditions





Reliability of the Predictions







Enabling Technology – BACnet

- What is BACnet?
- Benefits of a standard protocol
- What is the scope of BACnet?
- NIST BACnet Interoperability Testing Consortium
- ASHRAE formed SPC 135P (1987)
- 2,000 2,500 installed systems in 14 countries







BACnet Applications

- HVAC controls
- Lighting controls
- Security (access control)
- Fire detection/suppression systems
- Smart elevators
- Fault detection and diagnostic systems







Full Scale Demonstrations

 Important part of the project is "buy-in" from the fire service – does it work in the real world

Do through full scale demonstrations, press briefings, fire service involvement

First will be in New Castle County, Delaware

County executive, two fire companies, press

Congressional Fire Service – possible staff involvement

Promote Fire Service grants for equipment

Reverse role – EMT to provider

Next at NIST, then ?





County Municipal Office Building New Castle, Delaware







This is the Difficulty











Systems in Place









A Working Example

Gather sensor data from buildings

Simplex (Tyco) – NIST buildings

Edwards (SPX) – laboratory

Generate html pages (familiar), use http, J and JS


Delivery of information (accessible where needed)

Wired lines, Wireless





Array of Display Technologies













The Layout in Building 224

Outside

Corridor

Experiment











Active Systems


Special Equipment Building 224 Elevation

Building 224, 3rd Floor

Camera in A 346



Floor	Fire Size		
3	NА		
2	NA		
1	NA		



Current time: 3:32 PM





Status of the Project

Status of the NIST/NEMA Consortium Project

NFPA 72

Example of information delivery

Recent Presentations

Suppression and Detection Conference, Orlando, February, 2001

AUBE, March, 2001

The next step

Full scale rollout in New Castle, Delaware Honeywell panel, Ademco monitoring





Why is this high reliability?

- Information gathering is redundant
- Information can be shared by many Wired, Wireless, Standard protocols
- Validated algorithm for high likely-hood
- Metric for assured signal
- Actual threat
 Insult to people or structure (T, CO, ...)
- Confirmation thru data fusion

From a single sensor to 10 000 sensors (NIST)





Why is this important?

High reliability implies all *relevant* information is available when needed

Information gathering is redundant More information → Better decisions

Common display format

Wider use → safer buildings Information can be shared by many → Wired, Wireless

Metric for reliability

Validated algorithm for high likely-hood "If you cannot measure it, you don't understand it" (Lord Kelvin)

Actual threat

Insult to people or structure (T, CO, ...)





Who Benefits

Fire Service

Faster response

More efficient deployment

Fire Protection Engineering

Building management for fire safety

NIST

Metric for time series

Fire Safety Systems Manufacturers

Customer driven requirements





Conclusions

- It is important to improve information delivery systems as building protection moves from passive to active
- A standard interface will drive user demand
- Standard systems allow interconnect and thus a great deal of end-user appeal
- We are progressing as per our plan, moving into full scale

